

ADDENDUM-4

Dated: 27-08-2011

NAME OF WORK: DETAILED DESIGN, SUPPLY, INSTALLATION, TESTING, AND COMMISSIONING (INCLUDING INTEGRATED TESTING & COMMISSIONING) OF E&M, FIRE DETECTION, FIRE SUPPRESSION AND VAC SERVICES FOR 6 ELEVATED STATIONS, VIA DUCT LIGHTING AND LIGHTING OF RSS & TSS/ASS OF CAR DEPOT OF EAST WEST CORRIDOR OF KOLKATA METRO TENDER NO-EL-E&M-1.

No revised Tender Document will be issued. Addendum 4, however is to be read along with the Revised Tender Document for Tender EL-E&M-1(Revised) issued on 16.08.2011 as well as with Addendum 3 uploaded on kmrc website www.kmrc.in on 26.08.2011

Sr. No.	Volume Ref.	Clause/Section	As appeared in tender document	To be read as
1	3A	E01- 1.9- C- a1	3 nos. 5HP / 3.75 kW pump DOL starter with bimetallic over current relay + single phase preventer with potential free contact for remote monitoring and control	3 nos. 5HP / 3.75 kW pump(with a minimum head of 30 meters) DOL starter with bimetallic over current relay + single phase preventer with potential free contact for remote monitoring and control



CEE/KMRCL

Sl. No.	Clause ref.	Query	Reply	Addendum issued or not
A				
1	4-2 -VAC-Ductable BOQ	VAC boq calls for Environmental friendly refrigerant R407C/R134A . Many of the OEMs do not have Ductable split AC with refrigerants R407C & R134A . We request you to approve ductable split AC with R22 refrigerant	No change is contemplated	No
2	BOQ & drawings	We presume that the schedule of quantities takes precedence over drawings in case of discrepancies between the two. Please confirm.	No change. Clause 1.2(Vol. 4/3 Price Bid Document Payment Milestone) explains	No
3	4-1-(A) E.09	Domestic Water Pump	Required head is 30 mts. LPS may be calculated accordingly. Specification changed	Yes
	1	Supply at site, installation, testing and commissioning of 5HP/3.75 KW Pump, Base Frame with motor 415 V including cable/wire connection. We request you to provide the total Head in metres and capacity flow required in LPS for the pumpsets.		
4	4-1-(A) E.09	Domestic Water Pump		
	1	Supply at site, installation, testing and commissioning of 5HP/3.75 KW Pump, Base Frame with motor 415 V including cable/wire connection. We request you to provide the total Head in metres and capacity flow required in LPS for the pumpsets.		

Sl. No.	Clause ref.	Query	Reply	Addendum issued or not
5	4-1-(A) E.09	Domestic Water Pump		
	1	Supply at site, installation, testing and commissioning of 5HP/3.75 KW Pump, Base Frame with motor 415 V including cable/wire connection. We request you to provide the total Head in metres and capacity flow required in LPS for the pumpsets.		
6	4-1-(A) E.09	Domestic Water Pump		
	1	Supply at site, installation, testing and commissioning of 5HP/3.75 KW Pump, Base Frame with motor 415 V including cable/wire connection		
7	4-1-(A) E.09	Domestic Water Pump		
	1	Supply at site, installation, testing and commissioning of 5HP/3.75 KW Pump, Base Frame with motor 415 V including cable/wire connection. We request you to provide the total Head in metres and capacity flow required in LPS for the pumpsets.		
8	4-1-(A) E.09	Domestic Water Pump		
	1	Supply at site, installation, testing and commissioning of 5HP/3.75 KW Pump, Base Frame with motor 415 V including cable/wire connection. We request you to provide the total Head in metres and capacity flow required in LPS for the pumpsets.		