

ADDENDUM – 6**Date: - 13/09/2011**

Name of Work :- DETAILED DESIGN,SUPPLY,INSTALLATION,TESTING,AND COMMISSIONING (INCLUDING INTEGRATED TESTING AND COMMISSIONING OF E&M ,FIRE DETECTION,FIRE SUPPRESSION AND VAC SERVICES FOR SIX ELEVATED STATION,VIADUCT LIGHTING AND LIGHTING OF RSS & TSS/ASS OF CAR DEPOT OF EAST WEST CORRIDOR OF KOLKATA METRO TENDER NO.EL-E&M-1

No REVISED TENDER DOCUMENT WILL BE ISSUED.ADDENDUM 6,however is to be read along with the Revised Tender Document for Tender EL-E&M-1(Revised) issued on 16.08.2011 as well as with ADDENDUM 3 , ADDENDUM 4 and ADDENDUM 5 available on KMRCL website

www.kmrc.in

Revised tender drawing is now available in CD 'A' & CD ' B' which may be got collected from this office. Those who have purchased the tender document or drawing in CD earlier may collect the same free of cost.

Sr. No	Volume Ref.	Clause/Section	As appeared in Tender document	To be Read as
1	3 (Revised)	(F) ISMS Requirement	New clause added	The following points may please be noted and taken into consideration by the Tenderers while quoting for ISMS compatibility of their equipment. 1. ALL ACBs should have necessary Terminal for Telecommand and Telesignal facility to enable controlling of the Breaker from OCC/LCC. 2. All MCCBs having remote operation facility should also have terminals for Telecommand and Telesignal compatibility. 3. All other MCCBs/MCBs upto 63/100 Amps capacity should have terminal for transmitting Telesignals to OCC about their status. 4. Facility/terminals for transmitting

				<p>signal for telemetering of available data at the ASS should be provided by the tenderer.</p> <p>5. Terminal for Telecommand and Telesignal to enable controlling of Fire pumps and jockey pump from OCC/LCC.</p> <p>6. Terminal for Telesignalling of fire Detection system functioning to OCC/LCC.</p> <p>7. Terminal for telesignalling of Functioning of VAC equipment system at station to be monitored at OCC/LCC.</p> <p>8. Terminal for Clean Gas System alarm activation and monitoring at OCC/LCC.</p>
2	1	1.1.2 Key Details	<p>Date & Time of submission of tender(As appeared in Addendum-5)</p> <p>20th Sept 2011 at 15:00 Hrs</p>	<p>Date & Time of submission of tender.</p> <p>30th Sept 2011 at 15:00 Hrs</p>
			<p>Date & Time of Opening of tender(As appeared in Addendum-5)</p> <p>20th Sept 2011 at 15:30 Hrs</p>	<p>Date & Time of Opening of tender.</p> <p>30th Sept 2011 at 15:30 Hrs</p>